



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
LARGE DIAMETER CLEANOUTS (SAMPLING PORT)**

USING DEPARTMENT: Water Utility **ISSUED:** 10/01/97 **REVIEWED:** 01/01/15 **REVISED:** 01/01/15

PREPARED BY: Bill Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Large Diameter Cleanouts. Base shall have a U-shaped invert that is a smooth, large-radius, curved, continuation of the inside surfaces of the connecting pipes. Invert channel shall have a depth equal to the nominal diameter of the largest connecting pipe.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
10/01/97	G.P.K. PRODUCTS, INC. P.O. Box 2872 Fargo, ND 58102	Wastewater Access Chambers Riser Pipe: 24" diameter PVC meeting ASTM F679 PS115 SDR 26 HWS Connectors: PVC meeting ASTM D3034 SDR 26 Base: PVC (Bases are only for 6" through 12" diameter connecting pipes. Base shall have flat bottom that is at least 4" below the outside surface of the lowest connecting pipe. Invert to be coated, cast-in-place concrete placed by cleanout installation contractor.)	W. Flynn
01/02/98	L-F MANUFACTURING, INC. P.O. Box 578 Giddings, TX 78942	36" I.D. Fiberglass Unit with integral invert and cone— <u>60" maximum depth</u>	W. Flynn

NOTE: