

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 08/01/2023 - 08/31/2023

Parameter	Units				Davis WTP			Ullrich WTP			Handcox WTP
pH	SU	Avg	9.7	Avg	9.7	Avg	9.7	Avg	9.7	Avg	9.7
		Max	9.8	Max	9.9	Max	9.9	Max	9.7	Max	9.7
		Min	9.7	Min	9.6	Min	9.6	Min	9.6	Min	9.6
Total Alkalinity	mg/L as CaCO3	Avg	56	Avg	58	Avg	58	Avg	63	Avg	63
		Max	61	Max	62	Max	62	Max	71	Max	71
		Min	52	Min	56	Min	56	Min	60	Min	60
Total Hardness	mg/L as CaCO3	Avg	89	Avg	91	Avg	91	Avg	92	Avg	92
		Max	94	Max	95	Max	95	Max	99	Max	99
		Min	84	Min	89	Min	89	Min	90	Min	90
Total Solids	mg/L	Avg	198	Avg	207	Avg	207	Avg	221	Avg	221
		Max	222	Max	212	Max	212	Max	244	Max	244
		Min	164	Min	202	Min	202	Min	208	Min	208
Total Chloramines	mg/L	Avg	2.73	Avg	2.57	Avg	2.57	Avg	2.72	Avg	2.72
		Max	2.95	Max	2.75	Max	2.75	Max	2.90	Max	2.90
		Min	2.50	Min	2.35	Min	2.35	Min	2.55	Min	2.55
Total Organic Carbon	mg/L	Avg	2.72	Avg	2.64	Avg	2.64	Avg	2.67	Avg	2.67
		Max	2.94	Max	2.77	Max	2.77	Max	2.72	Max	2.72
		Min	2.57	Min	2.54	Min	2.54	Min	2.61	Min	2.61
Conductivity	umhos/cm	Avg	337	Avg	350	Avg	350	Avg	384	Avg	384
		Max	339	Max	350	Max	350	Max	384	Max	384
		Min	335	Min	350	Min	350	Min	384	Min	384
Total Trihalomethanes	ug/L	Avg	45.6	Avg	32.8	Avg	32.8	Avg	30.6	Avg	30.6
		Max	48.8	Max	32.8	Max	32.8	Max	30.6	Max	30.6
		Min	42.3	Min	32.8	Min	32.8	Min	30.6	Min	30.6
Turbidity	NTU	Avg	.07	Avg	.02	Avg	.02	Avg	.03	Avg	.03
		Max	.11	Max	.04	Max	.04	Max	.05	Max	.05
		Min	.04	Min	.02	Min	.02	Min	.02	Min	.02