



**CITY OF AUSTIN  
WATER QUALITY SUMMARY  
3rd Quarter 2020**

Average Results for Samples Collected July 1, 2020 to September 30, 2020										
CONSTITUENT (mg/L)	DWTP	UWTP	HWTP	DWTP		UWTP		HWTP		SDWA Tap MCL/[SMCL]
	Raw	Raw	Raw	Tap	Tap	Tap	Tap	Tap		
Total Ammonia (as N)	&	&	&	0.60		0.62		0.62		
Free Ammonia (as N)	<0.05	<0.05	<0.05	0.07		0.10		0.10		
Calcium	44	44	40	11		14		12		
Chloramines	&	&	&	2.81		2.70		2.78		
Fluoride	0.20	0.20	0.20	0.72		0.66		0.65		4/[2]
Magnesium	18	18	19	16		12		13		
Sulfate	◆	◆	◆	◆		◆		◆		[250]
Total Phosphate	◆	◆	◆	0.82		0.57		0.93		
Total Hardness (as CaCO <sub>3</sub> )	185	186	178	92		84		84		
pH (units)	8.1	8.0	8.4	9.7		9.6		9.7		[>7.0]
Conductivity (umhos/cm)	457	456	442	304		292		326		
Total Alkalinity (as CaCO <sub>3</sub> )	162	162	154	65		56		61		
Phenol Alkalinity (as CaCO <sub>3</sub> )	0	0	1	19		15		17		
Total Solids	◆	◆	◆	◆		◆		◆		[500]
Threshold Odor (TON)	4	4	4	0		0		0		[3]
Total Organic Carbon	3.90	3.60	3.59	2.46		2.19		2.26		
Turbidity (NTU)	◆	◆	◆	◆		◆		◆		0.3
Silica	◆	◆	◆	◆		◆		◆		
UV254 (cm <sup>-1</sup> )	◆	◆	◆	◆		◆		◆		
Total Coliform (Col/100ml)	◆	◆	◆	<1		<1		<1		
E.Coli (Col/100ml)	◆	◆	◆	<1		<1		<1		

< set of averaged measurements contains results that are less than the method detection limit

◆ Due to Covid-19 the number of analyses have been reduced. No data currently available.

Parameters listed below were collected and analyzed by TCEQ Contractors for compliance with the Safe Drinking Water Act.										
CONSTITUENT (mg/L)	DWTP Raw	UWTP Raw	HWTP Raw	Central Tap	Detection Limit	South Tap	Detection Limit	North Tap	Detection Limit	SDWA Tap MCL/[SMCL] in mg/L
<b>Disinfection By Products, Collected On:</b>				7/7/2020		7/7/2020		7/7/2020		
Haloacetic Acids (HAA5)	&	&	&	0.0111		0.0131		0.0116		0.060
Trihalomethane	&	&	&	0.0327		0.0309		0.0311		0.080
CONSTITUENT (mg/L)	DWTP Raw	UWTP Raw	HWTP Raw	DWTP Tap	Detection Limit	UWTP Tap	Detection Limit	HWTP Tap	Detection Limit	SDWA Tap MCL/[SMCL] in mg/L
<b>Pesticides, Collected On:</b>				8/2/2018		2/10/2020		2/6/2018		
Endrin	&	&	&	ND	0.00001	ND	0.00001	ND	0.00001	0.002
Lindane	&	&	&	ND	0.00002	ND	0.00002	ND	0.00002	0.0002
Methoxychlor	&	&	&	ND	0.0001	ND	0.0001	ND	0.0001	0.04
<b>Inorganics, Collected On:</b>				2/10/2020		2/10/2020		2/10/2020		
Chloride	&	&	&	37		37		42		[250]
Sodium	&	&	&	19.6		19.8		24.7		---
<b>Metals, Collected On:</b>				2/10/2020		2/10/2020		2/10/2020		
Aluminum	&	&	&	ND	0.0200	ND	0.0200	ND	0.0200	[0.05 - 0.2]
Arsenic	&	&	&	ND	0.0020	ND	0.0020	ND	0.0020	0.01
Barium	&	&	&	0.0086		0.0105		0.0121		2
Cadmium	&	&	&	ND	0.0010	ND	0.0010	ND	0.0010	0.005
Chromium	&	&	&	ND	0.0100	ND	0.0100	ND	0.0100	0.1
Copper	&	&	&	ND	0.0020	ND	0.0020	0.0086		1.3 **
Iron	&	&	&	0.014		ND	0.010	0.022		[0.3]
Lead	&	&	&	ND	0.0010	ND	0.0010	ND	0.0010	0.015 **
Manganese	&	&	&	ND	0.0010	ND	0.0010	ND	0.0010	[0.05]
Mercury	&	&	&	ND	0.00040	ND	0.00040	ND	0.00040	0.002
Nickel	&	&	&	ND	0.0010	ND	0.0010	ND	0.0010	[0.10]
Selenium	&	&	&	ND	0.0030	ND	0.0030	ND	0.0030	0.05
Silver	&	&	&	ND	0.0100	ND	0.0100	ND	0.0100	[0.1]
Antimony	&	&	&	ND	0.0010	ND	0.0010	ND	0.0010	0.006
Beryllium	&	&	&	ND	0.00080	ND	0.00080	ND	0.00080	0.004
Thallium	&	&	&	ND	0.00040	ND	0.00040	ND	0.00040	0.002
Zinc	&	&	&	ND	0.0050	ND	0.0050	0.0142		[5.0]

SDWA MCL = Safe Drinking Water Act Maximum Contaminant Level

SMCL = Secondary Maximum Contaminant Level standard recommended by TCEQ for aesthetic quality

\*\* = Action Levels

ND = Indicates levels are below detection limits of the instrumentation or method

& = No data available

col/100ml = Colonies per 100 milliliters

mg/L = milligrams per liter