

Drinking Water Quality Report  
Date Range: 01-FEB-2017 to 28-FEB-2017

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP		WTP 4	
				T2,T2H -----		T3 -----		T4 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.5	AVG	9.6
			MAX	9.7	MAX	9.7	MAX	9.7
			MIN	9.5	MIN	9.3	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	60	AVG	58	AVG	67
			MAX	64	MAX	62	MAX	73
			MIN	56	MIN	54	MIN	62
Total Hardness	MG/L	SM 2340 C	AVG	88	AVG	87	AVG	88
			MAX	96	MAX	95	MAX	96
			MIN	83	MIN	79	MIN	83
Total Solids	MG/L	SM 2540 B	AVG	142	AVG	130	AVG	146
			MAX	156	MAX	142	MAX	158
			MIN	106	MIN	112	MIN	136
Chloramines	MG/L	SM 4500-CL F	AVG	2.83	AVG	2.81	AVG	2.74
			MAX	3.00	MAX	3.05	MAX	2.98
			MIN	2.58	MIN	2.45	MIN	2.42
Sulfate	MG/L	SM 4500-SO4 E	AVG	34.0	AVG	39.0	AVG	38.0
			MAX	34.2	MAX	39.0	MAX	38.4
			MIN	33.6	MIN	39.0	MIN	38.4
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.76	AVG	2.68	AVG	2.80
			MAX	2.92	MAX	2.79	MAX	2.89
			MIN	2.60	MIN	2.51	MIN	2.73
Conductivity	UMHOS/cm	SM 2510 B	AVG	307	AVG	300	AVG	311
			MAX	308	MAX	300	MAX	311
			MIN	306	MIN	300	MIN	311
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	28.3	AVG	38.0	AVG	34.7
			MAX	29.9	MAX	39.4	MAX	39.2
			MIN	26.2	MIN	36.9	MIN	32.2
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.03	AVG	0.04
			MAX	0.10	MAX	0.06	MAX	0.07
			MIN	0.05	MIN	0.02	MIN	0.02