

Drinking Water Quality Report
Date Range: 01-JUN-2017 to 30-JUN-2017

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.7	MAX	9.7
			MIN	9.5	MIN	9.4	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	60	AVG	58	AVG	66
			MAX	64	MAX	61	MAX	70
			MIN	57	MIN	53	MIN	61
Total Hardness	MG/L	SM 2340 C	AVG	83	AVG	82	AVG	85
			MAX	88	MAX	86	MAX	88
			MIN	79	MIN	76	MIN	80
Total Solids	MG/L	SM 2540 B	AVG	149	AVG	137	AVG	158
			MAX	182	MAX	154	MAX	181
			MIN	122	MIN	121	MIN	134
Chloramines	MG/L	SM 4500-CL F	AVG	2.64	AVG	2.43	AVG	2.50
			MAX	2.85	MAX	2.60	MAX	2.60
			MIN	2.50	MIN	2.15	MIN	2.35
Sulfate	MG/L	SM 4500-SO4 E	AVG	29.0	AVG	32.0	AVG	35.0
			MAX	30.0	MAX	31.9	MAX	35.0
			MIN	28.8	MIN	31.9	MIN	35.0
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.84	AVG	2.66	AVG	2.72
			MAX	3.00	MAX	2.78	MAX	2.80
			MIN	2.71	MIN	2.49	MIN	2.67
Conductivity	UMHOS/cm	SM 2510 B	AVG	276	AVG	272	AVG	303
			MAX	276	MAX	274	MAX	304
			MIN	275	MIN	270	MIN	301
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	33.5	AVG	29.8	AVG	34.4
			MAX	47.0	MAX	38.3	MAX	35.5
			MIN	16.4	MIN	14.4	MIN	33.3
Turbidity	NTU	SM 2130 B	AVG	0.05	AVG	0.02	AVG	0.05
			MAX	0.07	MAX	0.03	MAX	0.07
			MIN	0.03	MIN	0.02	MIN	0.03